

CODE: MBK12-020CA-P1A

ERP: 0135259

Fire Extinguisher 2Kg CO2 EXCLUSIVE Portable

Fire Extinguisher 2Kg Carbon Dioxide with High Strength Front Outlet.

Height: 570mm

Galvanized bracket included

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	GTC, TSE, ITALY, VKF, NCP - KIWA, MED, MIRTEC, MPA DRESDEN, BENOR, APRAGAZ, CNBOP, NF
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	CO2
Capacity	2Kg
Extinguishing Agent	CO2
Operating Temperature	-20 to +60 °C
Max Allowable Pressure	174 bar
Test Pressure	250 bar
Volume of Equipment	3 L
Cylinder Height	415±1,5 mm
Cylinder Diameter	114 ± 1,14 mm
Cylinder Neck Thread	25E
Valve Material	HPb59-1 (Nikel Plated)
Cylinder Material	34CrMo4
Safety Valve	225±22,5 bar
Approx. gross Weight	6,5 kg
Approx. Dimensions	600 x 170 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK02-050CA-P1A

ERP: 0135034

Fire Extinguisher 5Kg CO2 EXCLUSIVE Portable

Fire Extinguisher 5Kg Carbon Dioxide with EDPM discharge hose with horn and plastic handle

Height: 760mm

Galvanized bracket included

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	NCP - KIWA, MED, MIRTEC, MPA DRESDEN, APRAGAZ, NF, BENOR, TSE, CNBOP, VKF, ITALY
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	CO2
Capacity	5Kg
Extinguishing Agent	CO2
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	169,3 bar
Test Pressure	250 bar
Volume of Equipment	7,5 L
Cylinder Height	655±6,55 mm
Cylinder Diameter	138 ± 1,38 mm
Cylinder Neck Thread	25E
Valve Material	HPb59-1 (Nickel Plated)
Cylinder Material	34CrMo4
Safety Valve	225±25 bar
Approx. gross Weight	14,5 kg
Approx. Dimensions	750 x 200 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK22-FFECO-6

ERP: 0501142

Fire Extinguisher 6 L with Ecological Fluorine Free Foam Fluorine Free

Fire Extinguisher 6 L water with additive, with one seam vessel, Internal Plastic Layer and Safety Release Valve. 100% PFAS FREE
METALLIC BRACKET INCLUDED [FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	BENOR, BSI, CNBOP, GTC, MED, NCP - KIWA, VKF
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	Fluor Free, Water
Capacity	6 L
Extinguishing Agent	Water with additive
Operating Temperature	+5 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	7,9 L
Cylinder Height	470±5 mm
Cylinder Diameter	160±1,5 mm
Cylinder Neck Thread	M30x1,5
Cylinder Material	DC01 (St12)
Valve Material	HPb59-1 (Nikel Plated)
Safety Valve	19-26 bar
Approx. gross Weight	10,5 kg
Approx. Dimensions	630x200 mm
Paint Finish	RAL 3000



Issue Date: 28/05/2025

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK13-060PA-P1LFR

ERP: 0135289

Fire Extinguisher 6Kg Dry Powder with Int. Cartridge Portable

Knob-Operated Fire Extinguisher 6Kg with one seam vessel.

METALLIC BRACKET INCLUDED

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	BENOR, MED, MIRTEC, APRAGAZ, NF, VKF
Extinguisher Type	Portable
Pressure Type	Cartridge
Suppression Agent Type	Powder
Capacity	6Kg
Extinguishing Agent	ABC 40%
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	7,8 L
Cylinder Height	455±5 mm
Cylinder Diameter	160±2 mm
Cylinder Neck Thread	M74x2
Valve Material	Al6061-T6
Cylinder Material	DC01 (St12)
Safety Valve	21-26 bar
Approx. gross Weight	9,34 kg
Approx. Dimensions	600x210 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P¹ str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK09-060PA-DF

ERP: 0135214

Fire Extinguisher 6Kg Dry Powder Portable

Fire Extinguisher 6Kg Dry Powder ABC 40% with one seam vessel and Pressure Gauge Safety Release Valve. -Metallic Bracket Included **Instructions for use printed on a sticker**



CHARACTERISTICS

Approval Type	ITALY, KKI, MED, MIRTEC, TSE, VKF
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	Powder
Capacity	6Kg
Extinguishing Agent	ABC 40%
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	7,8 L
Cylinder Height	450 ± 5 mm
Cylinder Diameter	160 ± 1.5 mm
Cylinder Neck Thread	M30x1,5
Valve Material	HPb59-1 (Nickel Plated)
Cylinder Material	DC01 (St12)
Safety Valve	19-26 bar
Approx. gross Weight	9,94 kg
Approx. Dimensions	600x200 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 10/10/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK20-060WMIN-P1L

ERP: 0135617

Fire Extinguisher 6Lt Water with Additive, Mist Technology, with Int. Cartridge Fluorine Free

Knob-Operated 6Lt Fire Extinguisher, with Mist Technology, one seam vessel and Internal Plastic Layer.

100% Fluorine Free

METALLIC BRACKET INCLUDED

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	BENOR, VKF
Extinguisher Type	Portable
Pressure Type	Cartridge
Suppression Agent Type	Fluor Free
Capacity	6Lt
Extinguishing Agent	Water with 15% additive
Operating Temperature	+5 to +60 °C
Max Allowable Pressure	20 bar
Test Pressure	30 bar
Volume of Equipment	7,3 L
Cylinder Height	435±2 mm
Cylinder Diameter	162±2 mm
Cylinder Neck Thread	M74x2
Valve Material	AA6061
Cylinder Material	DC01
Safety Valve	22-26 bar
Approx. gross Weight	9,34 kg
Approx. Dimensions	515x190 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK22-FFECO-9

ERP: 0501143

Fire Extinguisher 9 L with Ecological Fluorine Free Foam Fluorine Free

Fire Extinguisher 9 L water with additive, with one seam vessel, Internal Plastic. Layer and Safety Release Valve. 100% PFAS FREE
METALLIC BRACKET INCLUDED



CHARACTERISTICS

Approval Type	BENOR, BSI, CNBOP, GTC, MED, NCP - KIWA, VKF
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	Fluor Free, Water
Capacity	9 L
Extinguishing Agent	Water with additive
Operating Temperature	+5 ~+60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	11 L
Cylinder Height	525±5 mm
Cylinder Diameter	180±1,5 mm
Cylinder Neck Thread	M30x1,5
Cylinder Material	DC01 (St12)
Valve Material	HPb59-1 (Nikel Plated)
Safety Valve	19-26 bar
Approx. gross Weight	14,5 kg
Approx. Dimensions	700x220 mm
Paint Finish	RAL 3000



Issue Date: 28/05/2025

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK13-090PA-P1LFR

ERP: 0135290

Fire Extinguisher 9Kg Dry Powder with Int. Cartridge Portable

Knob-Operated Fire Extinguisher **9Kg** with one seam vessel.

METALLIC BRACKET INCLUDED

Black foot & valve: ERP: 0135496 CODE : MBK13 - 090PA - P1LFR (GER) [FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	APRAGAZ, BENOR, MED, MIRTEC, MPA DRESDEN, NF, VKF
Extinguisher Type	Portable
Pressure Type	Cartridge
Suppression Agent Type	Powder
Capacity	9Kg
Extinguishing Agent	ABC 40%
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	11,1 L
Cylinder Height	515±5 mm
Cylinder Diameter	180±1,5 mm
Cylinder Neck Thread	M74x2
Valve Material	AA6061-T6
Cylinder Material	DC01 (St12)
Safety Valve	21-26 bar
Approx. gross Weight	14,5 kg
Approx. Dimensions	640x230 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK09-090PA-DF

ERP: 0135215

Fire Extinguisher 9Kg Dry Powder Portable

Fire Extinguisher 9Kg with one seam vessel Pressure Gauge Safety Release Valve.

- METALLIC BRACKET INCLUDED

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	APRAGAZ, ASSURALIA, BENOR, GTC, ITALY, KKI, MED, MIRTEC, NCP - KIWA, NF, TSE, VKF
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	Powder
Capacity	9Kg
Extinguishing Agent	ABC40%
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	11,20 L
Cylinder Height	510 ± 5 mm
Cylinder Diameter	180 ± 1.5 mm
Cylinder Neck Thread	30 x 1.5
Valve Material	HPb59-1 (Nikel Plated)
Cylinder Material	DC01 (St12)
Safety Valve	19-26 bar
Approx. gross Weight	15,34 kg
Approx. Dimensions	650 x 220 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK20-090WMIN-P1L

ERP: 0135618

Fire Extinguisher 9Lt Water with Additive, Mist Technology, with Int. Cartridge Fluorine Free

Knob-Operated 9Lt Fire Extinguisher, with Mist Technology, one seam vessel and Internal Plastic Layer.

100% Fluorine Free

METALLIC BRACKET INCLUDED

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	VKF, BENOR
Extinguisher Type	Portable
Pressure Type	Cartridge
Suppression Agent Type	Fluor Free
Capacity	9Lt
Extinguishing Agent	Water with 15% additive
Operating Temperature	+5 to +60 °C
Max Allowable Pressure	20 bar
Test Pressure	30 bar
Volume of Equipment	10,78 L
Cylinder Height	493±2 mm
Cylinder Diameter	182±2 mm
Cylinder Neck Thread	M74x2
Valve Material	AA6061
Cylinder Material	DC01
Safety Valve	22-26 bar
Approx. gross Weight	15 kg
Approx. Dimensions	580x210 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK22-FFECO-6-P1L

ERP: 0501138

Fluorine Free Fire Extinguisher 6Lt with Int. Cartridge Fluorine Free

Fire Extinguisher 6Lt water with additive, with internal CO2 cartridge, with one seam vessel, Internal Plastic Layer and Safety Release Valve. 100% Fluorine Free **METALLIC BRACKET INCLUDED*** *With optional Foam Cartridge During Activation and Discharge of the CO2 Internal Cartridge, the Foam is Released and Mixed with Water so that the Extinguisher is Ready for Use.



CHARACTERISTICS

Approval Type	BENOR, BSI, MED, NF, VKF
Extinguisher Type	Portable
Pressure Type	Cartridge
Suppression Agent Type	Fluor Free
Capacity	6Lt
Extinguishing Agent	water with 1,5% additive A and 25% additive B
Operating Temperature	+5 to +60 °C
Max Allowable Pressure	20 bar
Test Pressure	30 bar
Volume of Equipment	8 L
Cylinder Height	470±5 mm
Cylinder Diameter	160±1.5 mm
Cylinder Neck Thread	M74x2
Valve Material	AA6061
Cylinder Material	St12 (DC01)
Safety Valve	21-26 bar
Approx. gross Weight	10.9 kg
Approx. Dimensions	570x180 mm
Paint Finish	RAL3000
Packaging Details	1pc



Issue Date: 30/06/2025

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK22-FFECO-9-P1L

ERP: 0501139

Fluorine Free Fire Extinguisher 9Lt with Int. Cartridge Fluorine Free

Fire Extinguisher 9Lt water with additive, with internal CO2 cartridge, with one seam vessel, Internal Plastic Layer and Safety Release Valve. 100% Fluorine Free **METALLIC BRACKET INCLUDED*** *Optional



CHARACTERISTICS

Approval Type	BENOR, BSI, MED, NF, VKF
Extinguisher Type	Portable
Pressure Type	Cartridge
Suppression Agent Type	Fluor Free
Capacity	9Lt
Extinguishing Agent	water with 1,5% additive A and 25% additive B
Operating Temperature	+5 to +60 °C
Max Allowable Pressure	20 bar
Test Pressure	30 bar
Volume of Equipment	11.25 L
Cylinder Height	530±5 mm
Cylinder Diameter	180±1.5 mm
Cylinder Neck Thread	M74x2
Valve Material	DC01 (St12)
Cylinder Material	AA6061-T6
Safety Valve	21-26 bar
Approx. gross Weight	15.5 kg
Approx. Dimensions	630x200 mm
Paint Finish	RAL3000
Packaging Details	1pc



Issue Date: 30/06/2025

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P¹ str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK19-LITHIUM-6

ERP: 0501128

Portable Fire Extinguisher 6Lt for Lithium Batteries Fluorine Free

Fire Extinguisher 6Lt Water with complement, with One Seam Vessel with INTERNAL PLASTIC LAYER and External thread, Pressure Gauge Safety Release Valve and Gauge non return Valve.

Appropriate for use at Lithium Batteries Fires.


Metallic Bracket Included

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	NF, VKF, CE, BENOR, ITALY, NCP - KIWA, MED, MIRTEC
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	Agent for Li-on Batteries, Fluor Free
Capacity	6Lt
Fire Rating	13A
Extinguishing Agent	MINERAL-BASED AGENT
Operating Temperature	+5°C ~ +60°C °C
Max Allowable Pressure	20 bar
Test Pressure	30 bar
Volume of Equipment	7,8 L
Cylinder Height	477±3 mm
Cylinder Diameter	162±2 mm
Cylinder Neck Thread	M74x1.5
Valve Material	DC04/DC03
Cylinder Material	AA6061 (anodized)
Safety Valve	22~27 bar
Approx. gross Weight	~10,2 kg
Approx. Dimensions	580x180 mm
Paint Finish	RAL3000



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P^a str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK19-LITHIUM-9

ERP: 0501129

Portable Fire Extinguisher 9Lt for Lithium Batteries Fluorine Free

Fire Extinguisher 9Lt Water with complement, with One Seam Vessel with INTERNAL PLASTIC LAYER and External thread, Pressure Gauge Safety Release Valve and Gauge non return Valve. Appropriate for use at Lithium Batteries Fires. Metallic Bracket Included.

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	NF, VKF, CE, BENOR, ITALY, NCP - KIWA, MED, MIRTEC
Extinguisher Type	Portable
Pressure Type	Stored Pressure
Suppression Agent Type	Agent for Li-on Batteries, Fluor Free
Capacity	9Lt
Fire Rating	13A
Extinguishing Agent	MINERAL-BASED AGENT
Operating Temperature	+5°C ~ +60°C °C
Max Allowable Pressure	20 bar
Test Pressure	30 bar
Volume of Equipment	12 L
Cylinder Height	528±4 mm
Cylinder Diameter	182±2 mm
Cylinder Neck Thread	M74x1.5
Valve Material	DC04/DC03
Cylinder Material	AA6061 (anodized)
Safety Valve	22~27 bar
Approx. gross Weight	~14,2 kg
Approx. Dimensions	640x200 mm
Paint Finish	RAL3000



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK20-200CO-VR

ERP: 0135609

Trolley Fire Extinguisher 20Kg CO2 BSI KITEMARK SERIES

20Kg CO2 Trolley Fire Extinguisher with 40Lt Cylinder with 5m Discharge Hose.

HIGH-PRESSURE EPDM Discharge Hose. HEAVY Duty Carriage and wheels, Valve Protection HANDLE.

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	BSI
Extinguisher Type	Trolley
Pressure Type	Stored Pressure
Suppression Agent Type	CO2
Capacity	20Kg
Extinguishing Agent	CO2
Operating Temperature	-30 ~ +60 °C
Max Allowable Pressure	160 bar
Test Pressure	250 bar
Volume of Equipment	30 L
Cylinder Height	1030±15 mm
Cylinder Diameter	225 mm
Cylinder Neck Thread	25E
Cylinder Material	37Mn
Valve Material	CuZn40Pb2
Safety Valve	220~250 bar
Approx. gross Weight	82 kg
Approx. Dimensions	790x630x1180 mm
Paint Finish	RAL 3000
Packaging Details	1 p.c.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK09-250PA-H1B

ERP: 0135202

Trolley Fire Extinguisher 25Kg Dry Powder Fire Extinguishers

Trolley Fire Extinguisher, 25Kg Dry Powder ABC 40%, with 5m Discharge Hose and Valve with Pressure Gauge Safety Release Mechanism. SILKSCREENED USAGE-MAINTENANCE INSTRUCTION LABEL 3rd Wheel added on the Front Side of the Fire Extinguisher Carriage for Easier Usage- Handling.

Soft Material is used in the retaining wreaths of the vessel to avoid injuries and oxidation

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	GTC, ITALY, MED, MIRTEC
Extinguisher Type	Trolley
Pressure Type	Stored Pressure
Suppression Agent Type	Powder
Capacity	25Kg
Extinguishing Agent	ABC40%
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	30 L
Cylinder Height	720±3 mm
Cylinder Diameter	250±1 mm
Cylinder Neck Thread	G2"
Valve Material	HPb59-1 (Nikel Plated)
Cylinder Material	DC01 (St12)
Safety Valve	22-28 bar
Approx. gross Weight	60,5 kg
Approx. Dimensions	1000x390 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



EN1866



ITALIAN
HOMOLOGATION

Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK24-250HGEL-LTH

ERP: 0501163

Trolley Fire Extinguisher 25L HGEL Special Type



CHARACTERISTICS

Suppression Agent Type	Agent for Li-on Batteries
Approval Type	BENOR, CE, MED, MIRTEC
Extinguisher Type	Trolley
Capacity	25
Extinguishing Agent	HydroGel BM 048
Operating Temperature	+5~+60 °C
Max Allowable Pressure	18 bar
Test Pressure	28 bar
Volume of Equipment	30±1 L
Cylinder Height	724±5 mm
Cylinder Diameter	254±2 mm
Cylinder Neck Thread	G2x11
Cylinder Material	HP295
Valve Material	HPb59-1
Safety Valve	22~28 bar
Approx. gross Weight	65 kg
Approx. Dimensions	1020x464x579 mm
Paint Finish	RAL3000



EN1866

BENOR

Issue Date: 20/08/2025

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK03-250AF-W1A

ERP: 0135085

Trolley Fire Extinguisher 25Lt Foam Trolley

Trolley Fire Extinguisher, 25Lt BSX 1,5%, with 5m Discharge Hose. Vessel with Internal Plastic layer. Valve with Gauge Safety Release Mechanism. SILKSCREENED USAGE-MAINTENANCE INSTRUCTION LABEL 3rd Wheel added on the Front Side of the Fire Extinguisher Carriage for Easier Usage- Handling.

Soft Material is used in the retaining wreaths of the vessel to avoid injuries and oxidation

- > VESSEL of 50mm Male Neck Thread
- > SEPARATE CARRIAGE mounted on the Vessel
- > Heavy Duty WHEELS
- > Double Edge Stainless steel valve SAFETY PIN
- > Discharge Hose with gun type controlled discharge nozzle, made from advanced property material, bearing stainless steel springs for preventing permanent deformations of the discharge hose.

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	MED, MIRTEC
Extinguisher Type	Trolley
Pressure Type	Stored Pressure
Suppression Agent Type	Foam
Capacity	25Lt
Extinguishing Agent	BSX233 1,5%
Operating Temperature	+5 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	30 L
Cylinder Height	720±3 mm
Cylinder Diameter	250±1 mm
Cylinder Neck Thread	G2"
Valve Material	DC01 (St12)
Cylinder Material	HPb59-1 (Nickel Plated)
Safety Valve	22-28 bar
Approx. gross Weight	59,6 kg
Approx. Dimensions	1100x420 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



EN1866



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644**ATHENS DISTRIBUTION CENTER:** SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986**NORTH GREECE DISTRIBUTION CENTER:** 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793**CENTRAL & EAST CRETE DISTRIBUTION CENTER:** P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151**www.mobiakfire.com**

CODE: MBK14-500PA-EXT

ERP: 0135323

Trolley Fire Extinguisher 50Kg Dry Powder external cartridge Trolley

50Kg Trolley Fire Extinguisher with 5m Discharge Hose. The external cartridge contains Nitrogen (N2) as propellant gas.

Soft Material is used in the retaining wreaths of the vessel to avoid injuries and oxidation

> SEPARATE CARRIAGE mounted on the Vessel

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	BSI, MED, MIRTEC, MPA DRESDEN
Extinguisher Type	Trolley
Pressure Type	Cartridge
Suppression Agent Type	Powder
Capacity	50Kg
Extinguishing Agent	ABC 40%
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	20 bar
Test Pressure	30 bar
Volume of Equipment	54 L
Cylinder Height	880±6 mm
Cylinder Diameter	300±1 mm
Cylinder Neck Thread	G2"
Valve Material	HP295
Cylinder Material	HPb59-1
Safety Valve	22-27 bar
Approx. gross Weight	85,3 kg
Approx. Dimensions	1330x550 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



EN1866



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX: +30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P¹ str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com

CODE: MBK14-500AF-EXT

ERP: 0135324

Trolley Fire Extinguisher 50lt foam with external cartridge BSI KITEMARK SERIES

50Lt Trolley Fire Extinguisher with 5m Discharge Hose. The external cartridge contains Carbon Dioxide (CO2) as propellant gas.

Soft Material is used in the retaining wreaths of the vessel to avoid injuries and oxidation 3rd Wheel has been added on the Front Side of the Fire Extinguisher Carriage for Easier Usage-Handling.

VESSELS WITH INTERNAL PLASTIC LAYER

> SEPARATE CARRIAGE mounted on the Vessel

> Heavy Duty WHEELS

> CUSTOMIZED Silk Screening or Instruction

Label available upon Request.

> Discharge Hose with gun type controlled discharge nozzle, made from advanced property material, baring stainless steel springs for preventing permanent deformations of the discharge hose.

[FIRE EXTINGUISHERS USER INSTRUCTIONS](#)



CHARACTERISTICS

Approval Type	BSI, MIRTEC
Extinguisher Type	Trolley
Pressure Type	Cartridge
Suppression Agent Type	Foam
Capacity	50Lt
Extinguishing Agent	Foam 6%
Operating Temperature	+5 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	28 bar
Volume of Equipment	55,5 L
Cylinder Height	900±5 mm
Cylinder Diameter	305±3 mm
Cylinder Neck Thread	M74x2
Valve Material	HP295
Cylinder Material	HPb59-1 (Nickel Plated)
Safety Valve	22-28 bar
Approx. gross Weight	92,1 kg
Approx. Dimensions	1270x600 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.



Issue Date: 24/09/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644

ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986

NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793

CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151

